



July 15, 2022

Client: Perkins PWA

PO Box 9

Perkins, OK 74059

Requested By: Chad Beitz



National
Environmental
Laboratory
Accreditation
Program
ODEQ TNI Certified

Sample Project Name: Wastewater Treatment Plant - Permit # OK0028801

Date Samples Received: July 07, 2022 Time: 13:49 sample temp upon arrival at lab = 11.10°C - On Ice

Matrix: Waste Water

Lab Log Numbers: **EG07093-01**

Work Order: EG07093

Report # EG07093-0715220910

EPA Lab ID#'s: **Stillwater OK00092 Tulsa OK00983 OKC OK00129 ICR OK 001**

Oklahoma Certification: Stillwater NELAP WasteWater, ODEQ 8316/ Drinking Water, DEQ D9602
NELAP Tulsa WasteWater, ODEQ 9905 / Drinking Water, DEQ D9901
Oklahoma City NELAP WasteWater ODEQ 7202 / Drinking Water, DEQ D9937

Kansas Certification: Stillwater NELAP CERT # E-10219

Method Reference: 40 CFR 136, 141, and 261 Methods for Chemical Analysis of Water and Wastes EPA-600/4-79-020, March 1983. Test Methods for Evaluating Solid Wastes, SW-846, Final Update III. Standard Methods 1998 (20th Edition), Standard Methods 2005 (21st Edition) and Standard Methods 2011 (22nd Edition) for the Examination of Water and Wastewater.

Analysis Reference: If qualifiers present in "Prep Info" or "Analysis Info", then analysis performed as follows: @= Tulsa Lab and * = OKC Lab. If no qualifiers present, then analysis performed at Stillwater Lab.

Accurate Environmental Laboratories certify that the test results performed at the Stillwater lab meet all requirements of NELAP. Any exceptions to this can be found in the report footer or Quality Control Section of the report.

This report is to only be replicated in its entirety.

Accurate Environmental sampling protocol was followed for any sampling performed by Accurate Field Services.

Sample: *Effluent: WWTP*

Location Code:

PWSID#:

Collection Type: Grab

Sample Time: 7/7/22 11:00

Lab Log# EG07093-01

Method/Parameter	Test	Result	Notes	PQL#	Prep Info	Analysis Info
BOD5 SM5210 B	Biochemical Oxygen Demand	21.0 mg/L		2.00	07/08/22 08:06 CPL	07/13/22 13:03 JGB
Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	26.9 mg/L		15.6	07/11/22 09:10 RMM	07/14/22 15:33 RMM

Notes and Definitions

MCL Analyte concentration may exceed Maximum Contaminant Limit (MCL) for EPA Primary or Secondary Drinking Water Regulations.

Analyte concentration may exceed regulatory limit.

PQL Practical Quantitation Limit - the method reporting limit (MRL) adjusted for any dilutions or other changes made to the sample to deal with interferences/matrix effects

BPQL Below Practical Quantitation Limit (if applicable).

The "Prep Date" of the QC analysis coincides with the characters of the appropriate QC Lab ID. (Example: 19 A 02 15 - BLK = 2019, Jan 2, Batch #15 - Blank)

Lab Manager



Quality Control Data

Blank Data

QC Lab #	Test Group	Test	Result	PQL	Flags
22G0803-BLK1	BOD5 SM5210 B	Biochemical Oxygen Demand	BPQL mg/L	2.00	
22G1116-BLK1	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	BPQL mg/L	2.50	

Laboratory Control Sample Data

Lab QC#	Test Group	Test Name	LCS Result	Spike Level	Units	% Rec.	Control Limits	Flags
22G0803-BS1	BOD5 SM5210 B	Biochemical Oxygen Demand	211	198.0	mg/L	107	84.6 - 115.4	
22G1116-BS1	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	213	250.0	mg/L	85	80 - 120	

* Complete Entire COC to be in Compliance*

RUSH Due Date _____



Chain of Custody

Client Name- **City of Perkins - Public Works Authority**
 Project Name- **Wastewater Treatment Plant - Permit # OK0028801**

Sample Preserv. & Container →	1000 ml Plastic				
Analysis Requested →	TSS / BOD				
# of Container ↓	2	x			

Accurate Work Order #	Date Sample Taken	Time Sample Taken	Matrix or Source (Refer. below)	Grab (G) or Comp (C)	Client I.D. / Sample Location or DEQ / EPA Location Code	Field Results (pH, Temp, Chlorine, ...) (note analysis & units)		
						pH	Temp C°	
E607993	7/7/22	1100	WW	G	Effluent: WWTP			
-01								

On-Site Info	Raw Alkalinity (TOC Raw)= _____ mg/L	Turbidity (E.Coli)= _____ ntu	Field Instrument Calibration -		
Matrix Codes	DW = Drinkingwater ;	WW = Wastewater ;	SL = Sludge ;	O = Other	
E.Coli Source	FS = Flowing Stream ;	RL = Reservoir Lake ;	GWUDI = Groundwater under direct influence of surface water		
Comments	Samples Delivered On Ice. Sample = Single Composite				

Meter Type	Standards	Final Read.	Date , Time	Initials
	4-7-10	7.05	7/7/22	ZI

Certification by Company Official: I hereby certify that the above sampling occurred during a period such that the sample(s) is/are representative of a typical operating day discharge for the above facility. Signature: *[Signature]* Date/Time: 7/7/22

Sampled By: Zachery Isca *[Signature]* Company: City of Perkins Sample Method: Grab

Relinquished By: Zachery Isca <i>[Signature]</i>	Date/Time: 7/7/22	Received By: Zachery Isca <i>[Signature]</i>	Date/Time: 7/7/22
Relinquished to Lab By: Zachery Isca <i>[Signature]</i>	Date/Time: 7/7/22	Received at Lab By: <i>[Signature]</i>	Date/Time: 7/7/22
Relq'd to Log-In Fridge By:	1349	Rec'd °C: 11.1	1349

Reporting Requirements (standard 10-15 working days) Compliance: No Oklahoma PWS ID # _____ RUSH Request (if available) _____ (Working Days)

Mail Report: Chad Beitz
 City of Perkins
 Address: PO Box 9, Perkins, OK 74059
 Phone #: 405-547-2445 Fax #: 405-547-5440
 Email: cbeitz@cityofperkins.net zisca@cityofperkins.net
 citymanager@cityofperkins.net cityclerk@cityofperkins.net

Mail Invoice: Accounts Payable
 City of Perkins Bid # - _____
 Address: Po Box 9, Perkins, OK 74059 PO # - _____
 Phone #: 405-547-2445 Fax #: 405-547-5440

www.accuratelabs.com (800) 516-5227
 505 South Lowry Street Stillwater, OK 74074 Phone: (405) 372-5300 Fax: (405) 372-5396
 4558 E. 40th Street Tulsa, OK 74145 Phone: (918) 663-5400 Fax: (918) 663-6300
 12036 N. Pennsylvania Oklahoma City, OK 73120 Phone: (405) 751-3132 Fax: (405) 751-3108