



January 23, 2023

Client: Okeene PWA

PO Box 800

Okeene, OK 73763

Requested By: -



National Environmental Laboratory Accreditation Program  
ODEQ TNI Certified

**Sample Project Name:** Drinking Water Coliform Analysis

**Date Samples Received:** January 18, 2023      Time: 17:40      sample temp upon arrival at lab = 6.00°C - On Ice

**Matrix:** Drinking Water

**Lab Log Numbers:**      **FA18039-01**      **FA18039-02**

**Work Order:** FA18039

**Report #** FA18039-0123231127

**EPA Lab ID#'s:** **Stillwater OK00092**    **Tulsa OK00983**    **OKC OK00129**    **ICR OK 001**

**Oklahoma Certification:** Stillwater NELAP WasteWater, ODEQ 8316/ Drinking Water, DEQ D9602  
NELAP Tulsa WasteWater, ODEQ 9905 / Drinking Water, DEQ D9901  
Oklahoma City NELAP WasteWater ODEQ 7202 / Drinking Water, DEQ D9937

**Kansas Certification:** Stillwater NELAP CERT # E-10219

**Method Reference:** 40 CFR 136, 141, and 261 Methods for Chemical Analysis of Water and Wastes EPA-600/4-79-020, March 1983. Test Methods for Evaluating Solid Wastes, SW-846, Final Update III. Standard Methods 1998 (20th Edition), Standard Methods 2005 (21st Edition) and Standard Methods 2011 (22nd Edition) for the Examination of Water and Wastewater.

**Analysis Reference:** If qualifiers present in "Prep Info" or "Analysis Info", then analysis performed as follows: @= Tulsa Lab and \* = OKC Lab. If no qualifiers present, then analysis performed at Stillwater Lab.

Accurate Environmental Laboratories certify that the test results performed at the Stillwater lab meet all requirements of NELAP. Any exceptions to this can be found in the report footer or Quality Control Section of the report.

This report is to only be replicated in its entirety.

Accurate Environmental sampling protocol was followed for any sampling performed by Accurate Field Services.

Sample: 701 N Main

Location Code: TC001

PWSID#: OK2000612

Collection Type: Grab

Sample Time: 1/18/23 9:20

Lab Log# FA18039-01

Method/Parameter	Test	Result	Notes	PQL#	Prep Info	Analysis Info
IDEXX Colilert P/A SM9223B	Total Coliform	Absent P/A			01/19/23 09:57 KEI	01/20/23 10:33 JM2
IDEXX Colilert P/A SM9223B	E. Coli	Absent P/A			01/19/23 09:57 KEI	01/20/23 10:33 JM2

Sample: 211 S Main

Location Code: TC002

PWSID#: OK2000612

Collection Type: Grab

Sample Time: 1/18/23 9:32

Lab Log# FA18039-02

Method/Parameter	Test	Result	Notes	PQL#	Prep Info	Analysis Info
IDEXX Colilert P/A SM9223B	Total Coliform	Absent P/A			01/19/23 09:57 KEI	01/20/23 10:33 JM2
IDEXX Colilert P/A SM9223B	E. Coli	Absent P/A			01/19/23 09:57 KEI	01/20/23 10:33 JM2

### Notes and Definitions

\_A Absent

MCL Analyte concentration may exceed Maximum Contaminant Limit (MCL) for EPA Primary or Secondary Drinking Water Regulations.

### Analyte concentration may exceed regulatory limit.

PQL Practical Quantitation Limit - the method reporting limit (MRL) adjusted for any dilutions or other changes made to the sample to deal with interferences/matrix effects

BPQL Below Practical Quantitation Limit (if applicable).

The "Prep Date" of the QC analysis coincides with the characters of the appropriate QC Lab ID. (Example: 19 A 02 15 - BLK = 2019, Jan 2, Batch #15 - Blank)

*Lab Manager*



## Quality Control Data

### Blank Data

QC Lab #	Test Group	Test	Result	PQL	Flags
23A1929-BLK1	IDEXX Colilert P/A SM9223B	Total Coliform	Absent P/A		
23A1929-BLK1	IDEXX Colilert P/A SM9223B	E. Coli	Absent P/A		

