



February 20, 2023

Client: Perkins PWA

PO Box 9

Perkins, OK 74059

Requested By: Chad Beitz



National
Environmental
Laboratory
Accreditation
Program
ODEQ TNI Certified

Sample Project Name: Wastewater Treatment Plant - Permit # OK0028801

Date Samples Received: February 10, 2023 Time: 9:17 sample temp upon arrival at lab = 9.80°C - On Ice

Matrix: Waste Water

Lab Log Numbers: **FB10006-01**

Work Order: FB10006

Report # FB10006-0220230917

EPA Lab ID#'s: **Stillwater OK00092 Tulsa OK00983 OKC OK00129 ICR OK 001**

Oklahoma Certification: Stillwater NELAP WasteWater, ODEQ 8316/ Drinking Water, DEQ D9602
NELAP Tulsa WasteWater, ODEQ 9905 / Drinking Water, DEQ D9901
Oklahoma City NELAP WasteWater ODEQ 7202 / Drinking Water, DEQ D9937

Kansas Certification: Stillwater NELAP CERT # E-10219

Method Reference: 40 CFR 136, 141, and 261 Methods for Chemical Analysis of Water and Wastes EPA-600/4-79-020, March 1983. Test Methods for Evaluating Solid Wastes, SW-846, Final Update III. Standard Methods 1998 (20th Edition), Standard Methods 2005 (21st Edition) and Standard Methods 2011 (22nd Edition) for the Examination of Water and Wastewater.

Analysis Reference: If qualifiers present in "Prep Info" or "Analysis Info", then analysis performed as follows: @= Tulsa Lab and * = OKC Lab. If no qualifiers present, then analysis performed at Stillwater Lab.

Accurate Environmental Laboratories certify that the test results performed at the Stillwater lab meet all requirements of NELAP. Any exceptions to this can be found in the report footer or Quality Control Section of the report.

This report is to only be replicated in its entirety.

Accurate Environmental sampling protocol was followed for any sampling performed by Accurate Field Services.

Sample: Effluent: WWTP

Location Code:

PWSID#:

Collection Type: Grab

Sample Time: 2/10/23 8:50

Lab Log# FB10006-01

Method/Parameter	Test	Result	Notes	PQL#	Prep Info	Analysis Info
BOD5 SM5210 B	Biochemical Oxygen Demand	54.7 mg/L		2.00	02/10/23 11:00 RMM	02/15/23 12:20 RMM
Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	154 mg/L		50.0	02/14/23 10:05 JM2	02/15/23 17:05 JM2
COD SM5220 D	Chemical Oxygen Demand	325 mg/L		15.0	02/14/23 09:16 RMM	02/14/23 13:17 RMM

Notes and Definitions

MCL Analyte concentration may exceed Maximum Contaminant Limit (MCL) for EPA Primary or Secondary Drinking Water Regulations.

Analyte concentration may exceed regulatory limit.

PQL Practical Quantitation Limit - the method reporting limit (MRL) adjusted for any dilutions or other changes made to the sample to deal with interferences/matrix effects

BPQL Below Practical Quantitation Limit (if applicable).

The "Prep Date" of the QC analysis coincides with the characters of the appropriate QC Lab ID. (Example: 19 A 02 15 - BLK = 2019, Jan 2, Batch #15 - Blank)

Lab Manager



Quality Control Data

Blank Data

QC Lab #	Test Group	Test	Result	PQL	Flags
23B1003-BLK1	BOD5 SM5210 B	Biochemical Oxygen Demand	BPQL mg/L	2.00	
23B1444-BLK1	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	BPQL mg/L	2.50	
23B1408-BLK1	COD SM5220 D	Chemical Oxygen Demand	BPQL mg/L	15.0	

Duplicate Sample Data

QC Lab #	Test Group	Test Name	Source	Dup Result	Samp Result	% RPD	RPD Limit	Flags
23B1003-DUP2	BOD5 SM5210 B	Biochemical Oxygen Demand	FB10006-01	54.8	54.7	0.2	20	

Laboratory Control Sample Data

Lab QC#	Test Group	Test Name	LCS Result	Spike Level	Units	% Rec.	Control Limits	Flags
23B1003-BS1	BOD5 SM5210 B	Biochemical Oxygen Demand	200	198.0	mg/L	101	84.6 - 115.4	
23B1408-BS1	COD SM5220 D	Chemical Oxygen Demand	977	1000	mg/L	98	90 - 110	
23B1444-BS1	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	244	250.0	mg/L	98	80 - 120	

* Complete Entire COC to be in Compliance*

RUSH Due Date _____



Chain of Custody

Sample Preserv. & Container →	1000 ml Plastic	1000 mL plastic			
Analysis Requested →	TSS / BOD	COD			
# of Container ↓					

Client Name- **City of Perkins - Public Works Authority**
 Project Name- **Wastewater Treatment Plant - Permit # OK0028801**

Accurate Work Order #	Date Sample Taken	Time Sample Taken	Matrix or Source (Refer. below)	Grab (G) or Comp (C)	Client I.D. / Sample Location or DEQ / EPA Location Code	Field Results (pH, Temp, Chlorine, ...) (note analysis & units)			# of Container ↓	TSS / BOD	COD
						pH	Temp °C				
FB10006	2/10/23	8:50	WW	G	Effluent: WWTP				2	x	x

On-Site Info	Raw Alkalinity (TOC Raw) = _____ mg/L	Turbidity (E.Coli) = _____ ntu	Field Instrument Calibration -		
Matrix Codes	DW = Drinkingwater; WW = Wastewater; SL = Sludge; O = Other		Meter Type	Standards	Final Read.
E.Coli Source	FS = Flowing Stream; RL = Reservoir Lake; GWUDI = Groundwater under direct influence of surface water			4-7-10	
Comments	Samples Delivered On Ice. Sample = Single Composite				

Certification by Company Official: I hereby certify that the above sampling occurred during a period such that the sample(s) is/are representative of a typical operating day discharge for the above facility.		Signature: <i>James Sauls</i>	Date/Time 2/10/23 08:30
Sampled By: James Sauls	Company: City of Perkins	Sample Method: Grab	
Relinquished By: <i>James Sauls</i>	Date/Time 2-10-23 08:50	Received By: <i>[Signature]</i>	Date/Time 2-10-23 8:50
□ Relinquished to Lab By: <i>[Signature]</i>	Date/Time 2/10/23 09:17	Received at Lab By: <i>[Signature]</i>	Date/Time 2/10/23 09:17

Reporting Requirements (standard 10-15 working days)	Compliance Reporting? No	Oklahoma PWS ID # OK 2006012	RUSH Request (if available)	_____ (Working Days)
Mail Report: Chad Beitz City of Perkins Address: PO Box 9 Perkins, OK 74059 Phone #: 405-547-2445 Fax #: 405-547-5440 Email: cbeitz@cityofperkins.net jsauls@cityofperkins.net citymanager@cityofperkins.net cityclerk@cityofperkins.net	Mail Invoice: Accounts Payable City of Perkins Bid # - _____ Address: Po Box 9 Perkins, OK 74059 PO # - _____ Phone #: 405-547-2445 Fax #: 405-547-5440			

www.accuratelabs.com (800) 516-5227	505 South Lowry Street Phone: (405) 372-5300 Stillwater, OK 74074 Fax: (405) 372-5396	6558 E. 40 th Street Phone: (918) 663-5400 Tulsa, OK 74145 Fax: (918) 663-6300	12036 N. Pennsylvania Phone: (405) 751-3132 Oklahoma City, OK 73120 Fax: (405) 751-3108
--	--	--	--