



May 05, 2023

Client: Perkins PWA

PO Box 9

Perkins, OK 74059

Requested By: Chad Beitz



National
Environmental
Laboratory
Accreditation
Program
ODEQ TNI Certified

Sample Project Name: Wastewater Treatment Plant-Permit #OK0028801

Date Samples Received: April 28, 2023 Time: 8:24 sample temp upon arrival at lab = 13.70°C - On Ice

Matrix: Waste Water

Lab Log Numbers: **FD28004-01**

Work Order: FD28004

Report # FD28004-0505230902

EPA Lab ID#'s: **Stillwater OK00092 Tulsa OK00983 OKC OK00129 ICR OK 001**

Oklahoma Certification: Stillwater NELAP WasteWater, ODEQ 8316/ Drinking Water, DEQ D9602
NELAP Tulsa WasteWater, ODEQ 9905 / Drinking Water, DEQ D9901
Oklahoma City NELAP WasteWater ODEQ 7202 / Drinking Water, DEQ D9937

Kansas Certification: Stillwater NELAP CERT # E-10219

Method Reference: 40 CFR 136, 141, and 261 Methods for Chemical Analysis of Water and Wastes EPA-600/4-79-020, March 1983. Test Methods for Evaluating Solid Wastes, SW-846, Final Update VI. Standard Methods 2005 (21st Edition), Standard Methods 2011 (22nd Edition), Standard Methods 2017 (23rd Edition) for the Examination of Water and Wastewater.

Analysis Reference: If qualifiers present in "Prep Info" or "Analysis Info", then analysis performed as follows: @= Tulsa Lab and * = OKC Lab. If no qualifiers present, then analysis performed at Stillwater Lab.

Accurate Environmental Laboratories certify that the test results performed at the Stillwater lab meet all requirements of NELAP. Any exceptions to this can be found in the report footer or Quality Control Section of the report.

This report is to only be replicated in its entirety.

Accurate Environmental sampling protocol was followed for any sampling performed by Accurate Field Services.

Sample: *Effluent:*

Location Code:

PWSID#:

Collection Type: Grab

Sample Time: 4/28/23 8:00

Lab Log# FD28004-01

Method/Parameter	Test	Result	Notes	PQL#	Prep Info	Analysis Info
BOD5 SM5210 B	Biochemical Oxygen Demand	146 mg/L		2.00	04/28/23 12:30 CPL	05/03/23 12:00 RMM
Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	360 mg/L		125	04/28/23 10:30 JM2	05/01/23 09:48 JM2

Notes and Definitions

MCL Analyte concentration may exceed Maximum Contaminant Limit (MCL) for EPA Primary or Secondary Drinking Water Regulations.

Analyte concentration may exceed regulatory limit.

PQL Practical Quantitation Limit - the method reporting limit (MRL) adjusted for any dilutions or other changes made to the sample to deal with interferences/matrix effects

BPQL Below Practical Quantitation Limit (if applicable).

The "Prep Date" of the QC analysis coincides with the characters of the appropriate QC Lab ID. (Example: 19 A 02 15 - BLK = 2019, Jan 2, Batch #15 - Blank)

Lab Manager



Quality Control Data

Blank Data

QC Lab #	Test Group	Test	Result	PQL	Flags
23D2817-BLK1	BOD5 SM5210 B	Biochemical Oxygen Demand	BPQL mg/L	2.00	
23D2830-BLK1	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	BPQL mg/L	2.50	

Duplicate Sample Data

QC Lab #	Test Group	Test Name	Source	Dup Result	Samp Result	% RPD	RPD Limit	Flags
23D2830-DUP2	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	FD28004-01	365	360	1	10	

Laboratory Control Sample Data

Lab QC#	Test Group	Test Name	LCS Result	Spike Level	Units	% Rec.	Control Limits	Flags
23D2817-BS1	BOD5 SM5210 B	Biochemical Oxygen Demand	194	198.0	mg/L	98	84.6 - 115.4	
23D2830-BS1	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	237	250.0	mg/L	95	80 - 120	

* Complete Entire COC to be in Compliance*

RUSH Due Date _____



Chain of Custody

Sample Preserv. & Container →	1000 ml Plastic	1000 ml Plastic	500ml Plastic		
Analysis Requested →	TSS / BOD	TSS / BOD	TDS		
# of Container ↓				I	x

Client Name- City of Perkins - Public Works Authority		Project Name- Wastewater Treatment Plant - Permit # OK0028801							
Accurate Work Order #	Date Sample Taken	Time Sample Taken	Matrix or Source (Refer. below)	Grab (G) or Comp (C)	Client I.D. / Sample Location or DEQ / EPA Location Code	Field Results (pH, Temp, Chlorine, ...) (note analysis & units)			# of Container ↓
						pH	Temp °C		
FD28004 - 01	4/28/23	8 am	WW	G	Effluent:				I

On-Site Info	Raw Alkalinity (TOC Raw)= _____ mg/L	Turbidity (E.Coli)= _____ ntu	Field Instrument Calibration -				
Matrix Codes	DW = Drinkingwater ; WW = Wastewater ; SL = Sludge ; O = Other _____		Meter Type	Standards	Final Read.	Date , Time	Initials
E.Coli Source	FS= Flowing Stream; RL= Reservoir Lake; GWUDI= Groundwater under direct influence of surface water		HACH				
Comments	Samples Delivered On Ice. (Effluent is Disinfected with Ultra Violet Light) -- All Glass containers provided by Accurate Labs have Teflon lined lids -- -- All samples are scheduled to be disposed of in 4 weeks of receipt at Accurate. -- -- Hazardous samples will be returned to client or will be disposed of for a fee --						
COC Date -							

Certification by Company Official: I hereby certify that the above sampling occurred during a period such that the sample(s) is/are representative of a typical operating day discharge for the above facility. Signature: James Sauls Date/Time 4-28-23 8am

Sampled By: James Sauls Company: City of Perkins Sample Method: GRAB

Relinquished By: <u>James Sauls</u>	Date/Time 4-28-23 8:00	Received By: <u>Traci Pearson</u>	Date/Time 4-28-23 8:00
<input type="checkbox"/> Relinquished to Lab By: <u>Traci Pearson</u>	Date/Time 4-28-23 8:26	Received at Lab By: <u>Christen Franklin</u>	Rec'd °C 13.7
<input type="checkbox"/> Relq'd to Log-In Fridge By:			Date/Time 4-28-23 0824

Reporting Requirements (standard 10-15 working days) Compliance Reporting? Yes or No (DMR,) Oklahoma PWS ID # OK 2006012 RUSH Request (if available) _____ (Working Days)

Mail Report To: chad beitz CBEITZ@cityofperkins.net jsauls@cityofpirkins.net City Manager - citymanager@cityofperkins.net Address: City of Perkins P.O. Box. 9 Perkins, Ok. 74059 Phone #: (405) 714-7859 Fax #: (405) 547-5440	Mail Invoice To: Bid # - _____ Address: City of Perkins P.O. Box. 9 Perkins, Ok. 74059 PO # - _____ Phone #: (405) 547-2445 Fax #: (405) 547-5440
---	--